

Schena, Cristeen

From: Kevin Stetson <kstetson@woodardcurran.com>
Sent: Monday, June 22, 2015 10:27 AM
To: david.burns@state.ma.us; Turin, David; ryan.joyce@state.ma.us; jdow@town.hull.ma.us; Aram Varjabedian; Frank Cavaleri
Subject: 6-21-15 11 Highland Ave, Hull, MA

We responded to a sewer manhole leaking call from the Hull Police at 11 Highland Ave. 8PM on June 21, 2015. The investigation discovered a manhole leaking a small amount onto the street and leaving a wet mark on the pavement, we found a blockage in the line at the manhole. The blockage was removed and the line was jetted and flow was verified. There was no overflow into any storm drains or water body. We will send you a completed SSO form. Please let me know if you need any other information at this point.

Kevin Stetson
Assistant Plant Manager
Hull WWTF
1111 Nantasket Ave.
Hull, MA, 02045
781-925-0906